

NOTICE IS HEREBY GIVEN THAT the Department of Financial Services, Division of State Fire Marshal, has received the petition for declaratory statement from Eric A. Neilinger. The petition was received on or about April 5, 2010. The petition seeks the agency’s opinion as to the applicability of the Florida Fire Prevention Code 2007 edition, NFPA 101 2006 9.6.2.5, 13.3.4.2.1(2), as it applies to the petitioner.

A clubhouse that is 100% sprinklered supervised by the fire alarm. One pull station was installed at main entrance. AHJ is requiring pull stations at all required exits contrary to code. Address of building affected by this petition is: 20281 East Country Club Drive, Aventura, FL. Question is: Can the AHJ require additional pull stations over and above the minimum one, per LS 101 based on their interpretation that as the AHJ they exceed the minimum and require additional pull stations at all required exits.

A copy of the Petition for Declaratory Statement may be obtained by contacting: Lesley Mendelson, Assistant General Counsel, 200 East Gaines Street, Tallahassee, Florida 32399-0340, (850)413-3604 or (850)413-4238; Fax: (850)922-1235 or (850)488-0697 (please advise if you would like it mailed or faxed to you and please include your phone number on your request in case any question arises) or e-mail your request to: Lesley.Mendelson@myfloridacfo.com.

**Section VIII  
Notices of Petitions and Dispositions  
Regarding the Validity of Rules**

**Notice of Petition for Administrative Determination has been filed with the Division of Administrative Hearings on the following rules:**

**NONE**

**Notice of Disposition of Petition for Administrative Determination have been filed by the Division of Administrative Hearings on the following rules:**

**NONE**

**Section IX  
Notices of Petitions and Dispositions  
Regarding Non-rule Policy Challenges**

**NONE**

**Section X  
Announcements and Objection Reports of  
the Joint Administrative Procedures  
Committee**

**NONE**

**Section XI  
Notices Regarding Bids, Proposals and  
Purchasing**

**DEPARTMENT OF EDUCATION**

Project: UF-361, IFAS Extension and Professional Development Center (Campus) Commissioning

**NOTICE TO PROFESSIONAL CONSULTANTS:**

The University of Florida Board of Trustees announces that Professional Services in the disciplines of engineering and architecture for Total Building Commissioning will be required for the project listed below:

Project: UF-361, IFAS Extension and Professional Development Center (Campus)

The project consists of the construction of a new two story approximately 14,000 GSF conference/office building. This facility will serve the needs for larger quality conferences and meetings, education programs and agricultural community functions. The building will be a multi-purpose facility providing for three individual conference/ meeting rooms, but allowing for the area to be opened for use as one large auditorium or lecture facility. All areas will provide for state-of-the art equipment for distance learning technology. This facility will serve as conference space for statewide centers to come together and share their research.

The scope of services shall include design phase peer review, completion and maintenance of the Owner’s Project Requirements (OPR) document, development of the Commissioning Plan and Commissioning Specifications, and construction phase pre-functional, functional, and performance testing for mechanical, electrical, building automation, and building envelope systems. The consultant shall also support project efforts to achieve higher-than-normal energy efficiency and attain (Gold) LEED certification.

Blanket professional liability insurance will be required for this project in the amount of \$1,000,000.

**INSTRUCTIONS:**

Firms desiring to apply for consideration shall submit a proposal only after thoroughly reviewing the facilities program, Project Fact Sheet for Commissioning Consultants, and other background information. The proposal shall be limited to 20 single-sided pages OR 10 double-sided, consecutively-numbered pages and shall include: