ABLE 1 TO § 141.201—VIOLATION CATEGORIES AND OTHER SITUATIONS REQUIRING A PUBLIC JOTICE—Continued

- (ii) Exceedance of the nitrate MCL by non-community water systems (NCWS), where granted permission by the primacy agency under 141.11 d) of his part.
- (iii) Exceedance of the secondar maxinum contaminant level (SMCL) for fluoride.
- (iv) Availability of unregulated contaminant monitoring data.
- (v) Other violations and situations determined by the primacy agency to require a public notice under this subpart, not already listed in appendix A.

(b) What type of public notice is required for each violation or situation? Public notice requireme lts are divided into three ties, to take into account the seriousness of the v olation or situation and of any tential adverse health effects that av be involved. The public notice requirements for each violation of tuation listed in Table 1 of this seddon are determined by the tier to which it is assigned. Table 2 of this sec n provides the definition of each tid. Appendix A of this part identifies the e tier assignment for each specific violation or situation.

TABLE 2 TO § 141/201—DEFINITION OF PUBLIC NOTICE TIEFS

(1) Tier 1 public notice—required for NPDWR violations and situations with significant potential to have serious adverse effects on human health as a result of short-term exposure.

(2) Tier 2 public notice—required for all other NPDWP violations and situations with potential to have serious adverse effects on human health.

(3) Tier is public notice—required for all other NPD //R violations and situations not included in Tier 1 and Tier 2.

(c) Who must be notified? (1) Each public vater system must provide public notice to persons served by the water system, in accordance with this subpart. Public water systems that sell or otherwise provide drinking water to ther public water systems (i.e., to consecutive systems) are required to giv

public notice to the owner or operate.
Of the consecutive system; the consecutive system is responsible for providing public notice to the persons it serves.

(2) If public water system has a violation in portion of the Astribution system that is physicall or hydraulically isolated from other parts of the distribution system, le primacy agency may allow the stem to limit distribution of the unlic notice to only persons served y that portion of the system which is out of compliance. y the prima Permission. agency for limiting listribution of he notice must be granted in writing.

(3) copy of the notice must also be sent to the primacy agency, in ac ordance with the requirements under (141.31(d).

§ 141.202 Tier 1 Public Notice—Form, manner, and frequency of notice.

(a) Which violations or situations require a Tier I public notice? Table 1 of this section lists the violation categories and other situations requiring a Tier 1 public notice. Appendix A to this subpart identifies the tier assignment for each specific violation or situation.

TABLE 1 TO § 141.202—VIOLATION CATEGORIES AND OTHER SITUATIONS REQUIRING A TIER 1 PUBLIC NOTICE

- (1) Violation of the MCL for total coliforms when fecal coliform or E. coli are present in the water distribution system (as specified in § 141.63(b)), or when the water system fails to test for fecal coliforms or E. coli when any repeat sample tests positive for coliform (as specified in § 141.21(e)); Violation of the MCL for *E. coli* (as specified in § 141.63(c));
- (2) Violation of the MCL for nitrate, nitrite, or total nitrate and nitrite, as defined in § 141.62, or when the water system fails to take a confirmation sample within 24 hours of the system's receipt of the first sample showing an exceedance of the nitrate or nitrite MCL, as specified in § 141.23(f)(2);

(3) Exceedance of the nitrate MCL by noncommunity water systems, where permitted to exceed the MCL by the primacy agency under §141.11(d), as required under §141.209;

- TABLE 1 TO § 141.202—VIOLATION CATEGORIES AND OTHER SITUATIONS REQUIRING A TIER 1 PUBLIC NOTICE—Continued
- (4) Violation of the MRDL for chlorine dioxide, as defined in § 141.65(a), when one or more samples taken in the distribution system the day following an exceedance of the MRDL at the entrance of the distribution system exceed the MRDL, or when the water system does not take the required samples in the distribution system, as specified in § 141.133(c)(2)(i);
- (5) Violation of the turbidity MCL under § 141.13(b), where the primacy agency determines after consultation that a Tier 1 notice is required or where consultation does not take place within 24 hours after the system learns of the violation;
- (6) Violation of the Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR) or Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) treatment technique requirement resulting from a single exceedance of the maximum allowable turbidity limit (as identified in appendix A), where the primacy agency determines after consultation that a Tier 1 notice is required or where consultation does not take place within 24 hours after the system learns of the violation:
- (7) Occurrence of a waterborne disease outbreak, as defined in § 141.2, or other waterborne emergency (such as a failure or significant interruption in key water treatment processes, a natural disaster that disrupts the water supply or distribution system, or a chemical spill or unexpected loading of possible pathogens into the source water that significantly increases the potential for drinking water contamination):
- (8) Detection of E. coli, enterococci, or coliphage in source water samples as specified in § 141.402(a) and § 141.402(b);
- (9) Other violations or situations with significant potential to have serious adverse effects on human health as a result of shortterm exposure, as determined by the primacy agency either in its regulations or on a case-by-case basis.
- (b) When is the Tier 1 public notice to be provided? What additional steps are required? Public water systems must:
- (1) Provide a public notice as soon as practical but no later than 24 hours

- after the system learns of the violation;
- (2) Initiate consultation with the primacy agency as soon as practical, but no later than 24 hours after the public water system learns of the violation or situation, to determine additional public notice requirements; and
- (3) Comply with any additional public notification requirements (including any repeat notices or direction on the duration of the posted notices) that are established as a result of the consultation with the primacy agency. Such requirements may include the timing, form, manner, frequency, and content of repeat notices (if any) and other actions designed to reach all persons served.
- (c) What is the form and manner of the public notice? Public water systems must provide the notice within 24 hours in a form and manner reasonably calculated to reach all persons served. The form and manner used by the public water system are to fit the specific situation, but must be designed to reach residential, transient, and nontransient users of the water system. In order to reach all persons served, water systems are to use, at a minimum, one or more of the following forms of delivery:
- (1) Appropriate broadcast media (such as radio and television);
- (2) Posting of the notice in conspicuous locations throughout the area served by the water system;
- (3) Hand delivery of the notice to persons served by the water system; or
- (4) Another delivery method approved in writing by the primacy agency.
- [65 FR 26035, May 4, 2000, as amended at 67 FR 1836, Jan. 14, 2002; 71 FR 65652, Nov. 8, 2006; 78 FR 10350, Feb. 13, 2013]

141.203 Tier 2 Public Notice—Formanner, and frequency of notice.

(a) Which violations or situations require a Tier's public notice? Table 1 of this section lists the violation categories and other structions requiring a Tier 2 public notice. Aspendix A to this subpart identifies the tree assignment for each specific violation or situation.