

been adopted as a part of the Florida Fire Prevention Code, and as such is not subject to review or interpretation in a Declaratory Statement.

Question D: Based on the explanation given relating to this structure, is the facility required to have a fire sprinkler system?

Response to Question D: Yes, because the building is an assembly occupancy over 12,000 square feet and, therefore, does not qualify for an exemption to NFPA 101 under subdivision 12.3.5.2(2).

A copy of the order may be obtained from: Gabriel Mazzeo, Attorney, Division of State Fire Marshal, 200 East Gaines Street, Tallahassee, Florida 32399-0340, (850)413-3604, or you may fax your request to fax number (850)922-1235. An unsigned but exact copy of the order is also available on the Division of State Fire Marshal website which may be accessed at: <http://www.fldfs.com/SFM/sfmdeclaratorysummaries.htm>.

NOTICE IS HEREBY GIVEN that the Department of Financial Services has issued an order disposing of the petition for declaratory statement filed by the Kenneth Perkins, Fire Chief, Escambia County Fire Rescue on July 12, 2005. The following is a summary of the agency’s disposition of the petition:

The 12,000 square feet in NFPA 1, subdivision 13.3.2.23.2, refers to the square footage of the entire constructed storage area, and not just the square footage used by the occupant for the storage of combustibles.

A copy of the order may be obtained from: Gabriel Mazzeo, Attorney, Division of State Fire Marshal, 200 East Gaines Street, Tallahassee, Florida 32399-0340, (850)413-3604, or you may fax your request to fax number (850)922-1235. An unsigned but exact copy of the order is also available on the Division of State Fire Marshal website which may be accessed at: <http://www.fldfs.com/SFM/sfmdeclaratorysummaries.htm>.

**Section VIII
Notices of Petitions and Dispositions
Regarding the Validity of Rules**

Notice of Petition for Administrative Determination has been filed with the Division of Administrative Hearings on the following rules:

NONE

Notice of Disposition of Petition for Administrative Determination have been filed by the Division of Administrative Hearings on the following rules:

NONE

**Section IX
Notices of Petitions and Dispositions
Regarding Non-rule Policy Challenges**

NONE

**Section X
Announcements and Objection Reports of
the Joint Administrative Procedures
Committee**

NONE

**Section XI
Notices Regarding Bids, Proposals and
Purchasing**

DEPARTMENT OF EDUCATION

NOTICE TO PROFESSIONAL CONSULTANTS

The University of North Florida, Board of Trustees, a public body corporate, announces that Professional Services in the discipline of Architectural and Engineering Consultant will be required for the project listed below:

Housing Administration & Student Health Services Building;
The project consists of approximately 33,000 GSF to serve the various needs of the residential student population on campus. Some of the major functions included in the building will be the Housing Administration Office, the Student Life Office, the Student Health Services Offices, multi-purpose meeting rooms, and a variety of other support and ancillary spaces. Blanket professional liability insurance will be required for this project in the amount of \$2,000,000 and will be provided as a part of Basic Services (each, aggregate and per occurrence).

INSTRUCTIONS:

Firms desiring to apply for consideration shall submit a letter of application.

The letter of application should have attached:

1. The most recent version of the “Professional Qualifications Supplement,” completed by the applicant. Applications on any other form will not be considered.
2. A copy of the applicant’s current Professional Registration Certificate from the appropriate governing board. An applicant must be properly registered at the time of application to practice its profession in the State of Florida. If the applicant is a corporation, it must be chartered by the Florida Department of State to operate in Florida.